



Business Inspection Checklist

Below are the minimum items to be inspected within a business:

- Adequate and unobstructed exits

- Adequate emergency lighting and exit signage

- Verify Fire Sprinkler Coverage (if applicable)

- Verify Fire Alarm Coverage (if applicable)

- Proper signage

- Address located on building in contrast and 6 inch numbers visible from the roadway

- Verify power disconnect

- For light hazard occupancy 5lb. 3A-40BC fire extinguishers shall be provided every 75 ft.
For moderate hazard occupancy 10 lb. 3A-40BC fire extinguishers shall be provided every 50 ft.

- General housekeeping and storage

- Electrical Panels labeled and maintained

Please contact the Fire Prevention office for additional requirements that may be applicable to your business at fireprevention@deland.org or 386-626-7042.